



ERNIE FLETCHER  
GOVERNOR

**ENVIRONMENTAL AND PUBLIC PROTECTION CABINET**

OFFICE OF HOUSING, BUILDINGS, AND CONSTRUCTION

101 SEA HERO ROAD, SUITE 100

FRANKFORT, KY 40601

TELEPHONE: (502) 573-0365

www.kentucky.gov

LAJUANA S. WILCHER  
SECRETARY

**MEMORANDUM**

**TO:** *All Interested Persons*

**FROM:**

  
\_\_\_\_\_  
*Albert S. Mitchell, State Fire Marshal*

**SUBJECT:** *815 KAR 30:060  
Underground Petroleum Storage Tank Certification Regulation*

On February 7, 1991, 815 KAR 30:060 became effective. Any person, firm or corporation that installs, removes or makes repairs to underground storage tank systems must be certified by the State Fire Marshal's office. Effective April 1, 1991, a permit for the installation of an underground storage tank system or component will not be issued unless the work is performed by a certified contractor. The application for certification is enclosed. To apply for certification, complete the application with supporting documentation, accompanied by non-refundable, non-transferrable application fee of \$300.00, plus \$50.00 test fee, (\$350.00 total) payable to the **Kentucky State Treasurer**. We will review the application and notify eligible contractors of test dates available.

Please note that you must specifically list the name and experience of the person who the company is designating to take the test.

Attached to the back of this regulation are methods of meeting the pollution liability requirements, publication references for study, and directions to the State Fire Marshal's office. Also included are instructions on how to change information once certification has been achieved. There will be additional fees involved in some instances.

*ASM/dc*

SFM/UPST #01  
August, 2001

Office of Housing, Buildings and Construction  
State Fire Marshal's Office  
Hazardous Materials Section  
101 Sea Hero Road, Suite 100  
Frankfort, Kentucky 40601-5405  
Telephone Number: (502)573-0382  
Fax Number: (502) 573-1004

**APPLICATION FOR CERTIFICATION AS AN UNDERGROUND TANK CONTRACTOR**

**Please return completed application to the above address.  
Remit payment by check or money order; payable to the Kentucky State Treasurer.**

Type of Certification: ☐ Installer/Remover ☐ Remover Only ☐ Liner Only  
☐ Probationary Installer/Remover ☐ Probationary Remover Only ☐ Cathodic Protection Only

Application Fee Enclosed: \$300.00 ☐ Yes ☐ No  
Examination Fee Enclosed: \$ 50.00 ☐ Yes ☐ No

PLEASE PRINT OR TYPE AND SIGN

1. Full Name of Qualifying Person: \_\_\_\_\_  
FIRST NAME INITIAL LAST NAME
2. Permanent Residence: \_\_\_\_\_  
STREET/BOX OFFICE NUMBER  
\_\_\_\_\_  
CITY COUNTY STATE ZIP CODE
3. Telephone Number: \_\_\_\_\_  
RESIDENCE BUSINESS
4. Social Security Number: \_\_\_\_\_ - \_\_\_\_\_ - \_\_\_\_\_
5. Birthdate: \_\_\_\_\_ - \_\_\_\_\_ - \_\_\_\_\_  
MONTH DAY YEAR
6. The Department of Housing, Buildings and Construction will provide reasonable modification in the administration of all licensure exams for qualified individuals with disabilities. The qualified individual with a disability shall submit, to the Department, documentation from an appropriate professional stating the limitations imposed by his/her disability. The individual with a disability shall request the effective modification. Do you have any disabilities? ☐ Yes ☐ No
7. Company Name: \_\_\_\_\_
8. Company Address: \_\_\_\_\_  
STREET/BOX OFFICE NUMBER  
\_\_\_\_\_  
CITY COUNTY STATE ZIP CODE
9. Federal Tax ID Number: \_\_\_\_\_
10. Number of years experience: Installer \_\_\_\_\_ Remover \_\_\_\_\_ Tank Liner \_\_\_\_\_ Cath. Prot. \_\_\_\_\_

11. *Experience:* The person making application shall demonstrate that within five (5) years immediately prior to making application, that he/she has participated in the installation of, performance of repairs on site to, closure of, removal of, or lining of a minimum of six (6) underground storage tanks.

1)

NAME OF PROJECT		
COMPANY NAME		
CITY	COUNTY	STATE
- - DATE WORK WAS PERFORMED	NUMBER OF TANKS	<input type="checkbox"/> Remove <input type="checkbox"/> Install <input type="checkbox"/> Repair <input type="checkbox"/> Upgrade <input type="checkbox"/> Line SCOPE OF WORK

2)

NAME OF PROJECT		
COMPANY NAME		
CITY	COUNTY	STATE
- - DATE WORK WAS PERFORMED	NUMBER OF TANKS	<input type="checkbox"/> Remove <input type="checkbox"/> Install <input type="checkbox"/> Repair <input type="checkbox"/> Upgrade <input type="checkbox"/> Line SCOPE OF WORK

3)

NAME OF PROJECT		
COMPANY NAME		
CITY	COUNTY	STATE
- - DATE WORK WAS PERFORMED	NUMBER OF TANKS	<input type="checkbox"/> Remove <input type="checkbox"/> Install <input type="checkbox"/> Repair <input type="checkbox"/> Upgrade <input type="checkbox"/> Line SCOPE OF WORK

4)

NAME OF PROJECT		
COMPANY NAME		
CITY	COUNTY	STATE
- - DATE WORK WAS PERFORMED	NUMBER OF TANKS	<input type="checkbox"/> Remove <input type="checkbox"/> Install <input type="checkbox"/> Repair <input type="checkbox"/> Upgrade <input type="checkbox"/> Line SCOPE OF WORK

11. *Experience (continued):*

5) \_\_\_\_\_  
NAME OF PROJECT

\_\_\_\_\_  
COMPANY NAME

\_\_\_\_\_  
CITY

\_\_\_\_\_  
COUNTY

\_\_\_\_\_  
STATE

\_\_\_\_\_  
DATE WORK WAS PERFORMED

\_\_\_\_\_  
NUMBER OF TANKS

☐ Remove ☐ Install ☐ Repair ☐ Upgrade ☐ Line  
SCOPE OF WORK

6) \_\_\_\_\_  
NAME OF PROJECT

\_\_\_\_\_  
COMPANY NAME

\_\_\_\_\_  
CITY

\_\_\_\_\_  
COUNTY

\_\_\_\_\_  
STATE

\_\_\_\_\_  
DATE WORK WAS PERFORMED

\_\_\_\_\_  
NUMBER OF TANKS

☐ Remove ☐ Install ☐ Repair ☐ Upgrade ☐ Line  
SCOPE OF WORK

12. List the name and address of at least three (3) professional references familiar with your work as a tank installer, remover, or liner.

1) \_\_\_\_\_  
FIRST NAME LAST NAME MI TELEPHONE NUMBER

\_\_\_\_\_  
ADDRESS

\_\_\_\_\_  
CITY

\_\_\_\_\_  
STATE

\_\_\_\_\_  
ZIP CODE

2) \_\_\_\_\_  
FIRST NAME LAST NAME MI TELEPHONE NUMBER

\_\_\_\_\_  
ADDRESS

\_\_\_\_\_  
CITY

\_\_\_\_\_  
STATE

\_\_\_\_\_  
ZIP CODE

3) \_\_\_\_\_  
FIRST NAME LAST NAME MI TELEPHONE NUMBER

\_\_\_\_\_  
ADDRESS

\_\_\_\_\_  
CITY

\_\_\_\_\_  
STATE

\_\_\_\_\_  
ZIP CODE

13. Attach proof of general liability insurance. (*Certificate of insurance* from a company authorized to do business in Kentucky.) Expiration Date: \_\_\_\_\_  
MONTH DAY YEAR

14. Attach proof of pollution liability insurance. (Certificate of insurance from an authorized insurer countersigned by a licensed Kentucky agent or from an eligible surplus lines insurer obtained through a Kentucky Surplus Lines Broker; surety bond from a Kentucky authorized company or an irrevocable letter of credit from an FDIC Kentucky Domicile Bank.) Expiration Date: \_\_\_\_\_

Specify Type:      ☐ Certificate of Insurance      ☐ Surety Bond      ☐ Letter of Credit

I, \_\_\_\_\_, hereby certify that the information contained on this application is true and correct to the best of my knowledge.

\_\_\_\_\_  
SIGNATURE OF APPLICANT FOR COMPANY

\_\_\_\_\_  
DATE

**NOTARIZED BY:**

State of: \_\_\_\_\_ County of: \_\_\_\_\_

Subscribed and Sworn to before me this \_\_\_\_\_ day of \_\_\_\_\_, 19 \_\_\_\_\_.

\_\_\_\_\_  
NOTARY PUBLIC

\_\_\_\_\_  
DATE MY COMMISSION EXPIRES

**815 KAR 30:060. Certification of underground petroleum storage tank contractors.**

RELATES TO: KRS 224.60-105, 224.60-135

STATUTORY AUTHORITY: KRS 224.60-135(5), 227.300

**NECESSITY, FUNCTION, AND CONFORMITY:** KRS 224.60-135(5) requires the State Fire Marshal to promulgate administrative regulations requiring a person or organization who installs, repairs, interior lines, installs corrosion protection, closes or removes an underground petroleum storage tank for an owner or operator to demonstrate financial capability, including maintenance of pollution liability insurance and technical competency and proficiency. This administrative regulation establishes the minimum requirements for determining technical competency and proficiency of a company who is responsible for the installation, repair, interior lining, installation of corrosion protection, removal or closure of a system by a qualifying individual and for determining financial capability through proof of insurance.

**Section 1. Definitions.** (1) "Certified contractor" means an individual or organization certified by the State Fire Marshal as qualified to:

(a) Engage in the business of installing, repairing, interior lining, installing corrosion protection, removing or closing a UPST system; or

(b) Supervise an employee engaged in an activity listed in paragraph (a) of this subsection.

(2) "Close" or "closure" means permanently taking an underground storage tank out of service without removing it from the ground.

(3) "Repair" means the restoration of a UPST system or component that:

(a) Has caused a release of a product from the system or the modification of the tank or a system component; and

(b) Does not include routine maintenance or corrosion protection applied to an existing installation, or the application of interior lining.

(4) "Remove" or "removal" means permanently taking an underground storage tank or a component out of service by removing it from the ground.

(5) "Routine maintenance" means servicing the UPST system or a component without excavation or making or the breaking of a connection below ground.

(6) "Underground storage tank" is defined by KRS 224.60-100(1).

(7) "Upgrade" means a modification or addition to a UPST system except routine maintenance.

(8) "UPST system" means an underground storage tank that is used solely for the storage of petroleum or a petroleum product.

**Section 2.** (1) A permit for the installation of a UPST system shall not be issued by the State Fire Marshal unless the applicant for the permit:

(a) Is certified by the State Fire Marshal's Office; and

(b) Assures the State Fire Marshal's Office, in writing, that the installation shall comply with all applicable requirements of the Natural Resources and Environmental Protection Cabinet promulgated in 401 KAR Chapter 42.

(2) An individual or company shall not install, remove, repair, interior line, install corrosion protection or close a UPST system unless the installation, removal, interior lining, installation of corrosion protection repair or closure:

(a) Is made by a certified contractor; and

(b) Complies with the applicable administrative regulations of the Natural Resources and Environmental Protection Cabinet, promulgated in 401 KAR Chapter 42.

(3) A certificate authorizing a company to engage in an activity regulated by this administrative regulation shall be issued under the name of the company if the company:

(a) Applies for the certification; and

(b) Has in its employ at least one (1) certified contractor who:

1. Meets the supervision requirements established in Section 3 of this administrative regulation; and

2. Shall:

a. Direct an employee engaged in an activity regulated by this administrative regulation; and

b. Exercise independent judgment regarding the recommendation of an activity to an employee acting under his direction.

Section 3. Supervision Requirements. (1) A certified contractor shall be present on site for each of the following activities:

(a) Preparation of the excavation immediately prior to receiving backfill or a component of the UPST system;

(b) Setting of the UPST system, including placement of an anchoring device, backfilling to the level of the UPST system and strapping;

(c) Installing piping and its components, field coating, or corrosion protecting piping and its components;

(d) Final inspection and pressure testing of a component of the tank or piping component of the UPST system; and

(e) Completion of the backfilling and filling of the excavation.

(2) A repair to a UPST system shall require a certified contractor to be present on site for each of the following activities:

(a) The actual excavation of an existing UPST system;

(b) The actual performance of a repair to the UPST system;

(c) The connection of a component of the piping during the repair project;

(d) The pressure testing of the UPST or its associated piping during the repair project;

(e) The replacement of a piping valve, fill pipe, vent, leak detection device, or spill and overflow protection device; and

(f) The addition of a leak detection device or spill and overflow device.

(3) Preparation for closing a UPST system shall require a certified contractor to be present on site for each of the following activities:

- (a) The cleaning and purging of a UPST system;
- (b) The filling of a UPST system with an inert solid material;
- (c) All testing associated with the cleaning and purging processes; and
- (d) The disconnection or capping of a component of the UPST system during the closing.

(4) Removal of a UPST system shall require a certified contractor to be present on site during each of the following activities:

- (a) The cleaning and purging of the UPST system;
- (b) The actual excavation and removal of the UPST system or a component;
- (c) All testing associated with the cleaning and purging processes; and
- (d) The disconnection or capping of a component of the UPST system during the removal.

(5) The interior tank lining of a UPST system shall require a certified contractor to be present on site during each of the following activities:

- (a) The cleaning and purging of the UPST system;
- (b) The excavation of the tank top;
- (c) The cutting of the top of the tank;
- (d) The entry of the tank;
- (e) The preparation of the interior of the tank;
- (f) The application of the lining of the tank; and
- (g) The closing and testing of the tank.

(6) The installation of corrosion protection to a UPST system shall require a certified contractor to be present on site during each of the following activities:

- (a) Excavation; and
- (b) The installation of an approved corrosion protection system.

Section 4. Certificate Availability. Each certified contractor shall have a copy of the current certificate issued by the State Fire Marshal at the location where he is supervising work. Upon request of a fire official or agent of the Natural Resources and Environmental Protection Cabinet, a certified contractor shall make the current certificate available for inspection.

Section 5. Application for Certification Requirements. Each applicant for certified contractor shall:

- (1) Submit an application accompanied by a nonrefundable fee of \$300, to the State Fire Marshal, on application

form "SFM/UPST #01, May, 2001", which is incorporated by reference in Section 11 of this administrative regulation;

(2) Be an individual at least eighteen (18) years of age;

(3) Verify to the State Fire Marshal the individual's experience in the installation of, performance of repairs on site to, interior lining of, installation of corrosion protection, closure and removal of UPST systems, as required by Section 6 of this administrative regulation;

(4) Complete the examination requirements of Section 7 of this administrative regulation;

(5) Provide proof of financial capability for taking corrective action and for compensating a third party for bodily injury or property damage by submitting certificates of general liability insurance in the minimum amount of \$500,000 and pollution liability insurance or other proof of financial capability to respond to damages in the minimum amount of \$25,000 per occurrence; and

(6) If the individual wishes the certificate to be issued with a company name, indicate the company name on the application form. The company shall provide the insurance certificates required by subsection (5) of this section and be subject to this administrative regulation.

Section 6. Experience Requirements. (1) The person making application shall demonstrate that within five (5) years immediately prior to making application, that he has participated in the installation of, performance of repairs on site to, closure of, interior lining of, installation of corrosion protection to, or removal of a minimum of six (6) underground storage tanks, except that:

(a) Technical training of the type provided and documented by the manufacturer of the underground storage tanks and approved by the State Fire Marshal shall reduce the experience requirements of this subsection by one-third (1/3); or

(b) A BS degree in engineering with a concentration in the area of underground containment systems or a Kentucky license to practice engineering shall reduce the experience requirements of subsection (1) by two-thirds (2/3).

(2)(a) An applicant requesting installer or remover certification shall:

1. Have installed at least three (3) UPST systems;

2. Meet the experience requirements established in subsections (3), (4), and (5) of this section.

(b) A certified installer or remover shall be qualified to perform work on a UPST system.

(3) An applicant requesting contractor certification pursuant to this administrative regulation for the limited function of removal and closure shall demonstrate experience in removal and closure of six (6) underground storage tanks.

(4) An applicant requesting contractor certification pursuant to this administrative regulation for the limited function of tank lining shall demonstrate experience in lining of six (6) underground storage tanks or provide proof of certification from the tank interior lining manufacturer or supplier of lining material.

(5) An applicant requesting certification pursuant to this administrative regulation for the limited function of installing corrosion protection shall demonstrate experience in the installation of six (6) corrosion protection systems.

Section 7. Probationary Certification. If the applicant does not comply with the level of experience required by Section 6 of this administrative regulation, the applicant shall receive a probationary certificate under the following conditions:

- (1) An applicant shall obtain a minimum score of eighty-five (85) percent on the written examination;
- (2) An applicant shall complete three (3) applicable UPST activities for which the applicant seeks certification within one (1) year of the issuance of the certificate;
- (3) All UPST activities shall comply with applicable codes and statutes;
- (4) An applicant shall not install, interior line, install corrosion protection, remove, close, backfill around or cover a tank installation during the probationary period without prior approval of the State Fire Marshal's office; and
- (5) An applicant shall pay a \$100 add-on inspection fee for each site where a tank is removed, closed, installed, upgraded or repaired by the applicant.

Section 8. Examination Requirements. Each applicant for certified contractor shall take and pass a written examination administered by the State Fire Marshal in compliance with this section.

- (1) The applicant shall submit payment of a fifty (50) dollar nonrefundable fee at least ten (10) days prior to the date of examination.
- (2) The examination for certification as an installer or remover shall be a written multiple choice examination covering all aspects of the installation, repair, interior lining, installation of corrosion protection, closure, and removal of underground petroleum storage tank systems. The examination shall test the applicant's knowledge of codes, standards, laws and administrative regulations and of current technological and industry recommended practices with respect to the proper installation, repair, interior lining, installation of corrosion protection, closure, and removal of UPST systems.
- (3) An applicant who requests to be a certified contractor for the limited purpose of removing and permanently closing a UPST system shall be tested on knowledge of closure and removal.
- (4) An applicant who requests to be a certified contractor for the limited function of interior lining of UPST systems shall be tested on knowledge of cleaning, and lining the interior of an underground petroleum storage tank.
- (5) An applicant who requests to be a certified contractor for the limited purpose of installing corrosion protection shall be tested on the installation, monitoring and general knowledge of a cathodic protection system.
- (6) An applicant may request permission to take the examination orally, upon good cause shown.
- (7) An applicant shall obtain a minimum score of seventy-five (75) percent on the written examination to satisfactorily pass.
- (8) An applicant who fails the examination may request reexamination upon payment of a nonrefundable twenty-five (25) dollar fee. An application shall remain pending for that purpose for a period of one (1) year after the date the application was submitted. If the applicant has not requested reexamination within the one (1) year period, the applicant shall file a new application for certification with the State Fire Marshal.
- (9) An examination shall be given monthly in the State Fire Marshal's Office located at 1047 U.S. 127 South, Frankfort, Kentucky.
- (10) An examination shall be graded and the applicant notified on the day of the examination. An examination paper:
  - (a) Shall not be returned to the applicant; and
  - (b) May be reviewed by the applicant on the day of the examination.
- (11) With the application, the State Fire Marshal shall furnish the applicant with a set of instructions and sample

examination questions. Instruction sheets shall refer the applicant to appropriate laws, administrative regulations and industry publications.

**Section 9. Certification and Renewal Procedures.** (1) The State Fire Marshal shall issue a certificate to each individual as required by Sections 5 through 7 of this administrative regulation. Each certificate shall be renewed annually for a fee of \$100 on Form SFM/UPST #02, May, 2001.

(2) The application or renewal for a certified contractor shall be denied by the State Fire Marshal if the applicant:

(a) Fails to provide the:

1. Information required by the application form SFM/UPST #01;
2. Insurance or financial responsibility certificates; or
3. the fee required for application and examination;

(b) Fails to comply with the experience and education requirements of this administrative regulation;

(c) Fails to successfully pass the examination required by this administrative regulation; or

(d) Makes a misrepresentation or submits a false statement with the application.

(3) A certified contractor who fails to renew his certification within a one (1) year period from the most recent expiration date of his certification shall:

(a) Be treated as a new applicant;

(b) Retake the examination; and

(c) Comply with the new applicant requirements.

**Section 10. Revocation or Suspension of Certification.** A certificate issued pursuant to this administrative regulation shall be suspended or revoked by the State Fire Marshal if:

(1) The certified contractor negligently, incompetently, recklessly or intentionally violated a provision of this administrative regulation or a required code relating to installation, repair, lining, closure or removal;

(2) The certified contractor recklessly or intentionally caused or permitted a person under the contractor's supervision to install, perform a repair on site to, interior line, install corrosion protection, close, or remove a UPST system in violation of 815 KAR 10:060;

(3) The certified contractor obtained the certification through fraud or misrepresentation;

(4) The individual who took the examination, provided the experience requirements and requested the certificate to be issued with a company's name and proof of insurance is no longer employed by the company in whose name the certificate was issued; or

(5) The certified contractor failed to renew the certification in accordance with Section 9 of this administrative regulation.

**Section 11. Incorporation by Reference.** (1) The following material is incorporated by reference:

(a) Form SFM/UPST #01, "Application for Certification as an Underground Tank Contractor", May, 2001; and

(b) Form SFM/UPST #02, "Installer/Remover Certification Renewal Form", May, 2001.

(2) This material may be inspected, copied or obtained, subject to applicable copyright law, at the State Fire Marshal's Office, Division of Hazardous Materials, 101 Sea Hero Rd., Ste.100, Frankfort, Kentucky 40601, Monday through Friday, 8 a.m. to 4:30 p.m. (17 Ky.R. 1890; Am. 2205; 2442; 2-7-91; 18 Ky.R. 493; 1038; 1342; eff. 10-8-91; 19 Ky.R. 1913; 2423; eff. 5-10-93; 22 Ky.R. 2342; eff. 8-1-96; 23 Ky.R. 1780; 2518; eff. 12-11-96; 24 Ky.R. 1397; 1679; eff. 2-17-98; 27 Ky.R. 3377; eff. 8-15-2001.)

***POLLUTION LIABILITY INSURANCE FOR UNDERGROUND  
PETROLEUM STORAGE TANK CONTRACTORS***

In order to comply with 815 KAR 30:060, the following methods shall be acceptable for satisfying the \$25,000.00 pollution liability, per occurrence, criteria for certification as a K Underground Petroleum Storage Tank Contractor.

Specifically, it is the intention of the regulation (815 KAR 30:060) that the original application and each renewal application for certification shall be accompanied by a certificate or written statement that the applicant has pollution liability insurance in the amount of \$25,000.00 for the year of certification. One of the following methods may be used:

1. A certificate from a licensed KY agent or KY Surplus Lines Broker that the insurance policy covers liability damage from pollution up to the sum equal to \$25,000 per occurrence. \$25,000 aggregate is acceptable.
2. A Surety Bond from a KY licensed company that it will be responsible for a sum of up to \$25,000 for pollution damage caused by a contractor during that year.
3. A letter of credit from an FDIC KY domiciled bank with an irrevocable guarantee to lend to the contractor up to \$25,000 as reparations for pollution damage caused by the company.

The certificate of insurance, surety bond, or letter of credit must be renewed annually upon application for the period of the certification. The terms of the bond or letter of credit will be reviewed for the appropriate language prior to acceptance by the Department. A sample letter of credit or sample surety bond form is available upon request which provides appropriate language requirements.

Also, any company which is also an owner of the tanks may satisfy the pollution liability portion of the regulation and legislation by showing that it conforms to the requirements of the Petroleum Storage Tank Environmental Assurance Fund Commission pursuant to S 224.817.

Anna F. Cole, UST Certification Secretary III  
(502) 573-0382, extension 420

***STUDY MATERIALS LIST  
FOR  
UGST CERTIFICATION TEST***

**American Petroleum Institute**

1220 L Street, Northwest  
Washington, DC 20005  
(202) 682-8000

**Publications Needed:**

Installation of Underground Storage Systems  
**API Recommended Practice #1615**

Removal & Disposal of Used UG Petroleum Storage Tanks  
**API Recommended Practice #1604**

Cathodic Protection of UG Petroleum Storage Tank &  
Piping Systems  
**API Recommended Practice #1632**  
**(Installer/Remover & Cathodic Protection Tests Only)**

Cleaning Petroleum Storage Tanks  
**API Recommended Practice #2015**

Interior Lining of Underground Storage Tanks  
**API Recommended Practice #1631 (Tank Liners Test Only)**

**Petroleum Equipment Institute**

P. O. Box 2380  
Tulsa, OK 74101-2380  
(918) 494-9696

**Publication Needed:**

Installation of Underground Liquid Storage Systems  
**PEI Recommended Practice 100-94**

## **STUDY MATERIALS LIST, continued**

### **Page 2**

#### **Other Sources:**

National Leak Prevention Association  
**NLPA Standard 631, Chapters A & B (Tank Liners TestOnly)**

NACE International  
P O Box 218340  
Houston, TX 77218-8340  
(713) 492-0535  
**NACE Standard RP0285-95 (Cathodic Protection Test Only)**

Federal Register; Environmental Protection Agency  
Underground Storage Tanks; Technical Requirements  
(502) 564-6716, Underground Tank Section  
**40 CFR, Part 280, Final Rules**

National Fire Protection Association  
Batterymarch Park  
Quincy, MA 02269  
(800) 344-3555  
**Flammable & Combustible Liquids Code, NFPA 30**  
**Auto & Marine Service Station Code, NFPA 30A**  
**National Electrical Code, NFPA 70**

## ***SAMPLE TEST QUESTIONS***

### ***Steel Tank Institute***

1. *When installing dielectric bushings in a cathodically protected steel tank, prior to placing the tank in the excavation, you should:*
  - a. *Cross-thread the bushings, because they seal better that way.*
  - b. *Install the bushings while the tank is under pressure.*
  - c. *Make sure that no electric current can pass through the dielectric flanges or bushings.*
  - d. *All of the above.*

### ***Petroleum Equipment Institute, RP 100***

2. *According to specifications issued by FRP tank manufacturers, hold down straps used for mechanically anchoring FRP tanks should:*
  - a. *Be placed on any convenient rib of the tank.*
  - b. *Be placed between the ribs.*
  - c. *Have anchor points at the bottom of the hole aligned within one (1) inch of the designated rib.*
  - d. *Be positioned according to recommendations of the manufacturer.*

### ***Petroleum Equipment Institute, RP 100***

3. *In a cathodically protected steel underground piping system, components such as dispensers, submerged pumps, and tanks which you do not intend to be protected by the cathodic protection system should be:*
  - a. *Electrically grounded to the piping.*
  - b. *Electrically isolated from the piping.*
  - c. *Electrically connected to the piping.*
  - d. *Electrically connected to the tank.*

*Sample Test Questions, cont.*

*American Petroleum Institute, RP 1632*

4. Two metals commonly used as sacrificial anodes to protect buried steel structures from corrosion are:
- a. Cast iron and zinc.
  - b. Zinc and magnesium.
  - c. Brass and copper.
  - d. Magnesium and malleable iron.

*American Petroleum Institute, RP 1604*

5. Using steam to clean and vapor-free a tank can be used under certain circumstances. The primary concern in using this type of method is:
- a. Magnetic resonance loss.
  - b. Corrosion enhancement.
  - c. Viscosity limitations.
  - d. Static electricity build-up.

**ANSWERS:**

- |    |     |                                  |                                  |                                  |
|----|-----|----------------------------------|----------------------------------|----------------------------------|
| 1. | (a) | (b)                              | <input checked="" type="radio"/> | (d)                              |
| 2. | (a) | (b)                              | (c)                              | <input checked="" type="radio"/> |
| 3. | (a) | <input checked="" type="radio"/> | (c)                              | (d)                              |
| 4. | (a) | <input checked="" type="radio"/> | (c)                              | (d)                              |
| 5. | (a) | (b)                              | (c)                              | <input checked="" type="radio"/> |

**NOTE:**

*These test questions are taken from PEI, Api, UL Inc, NFPA, ASTM, and NACE.*

## **INSTRUCTIONS FOR CHANGING EMPLOYMENT OR CHANGING COMPANY NAME**

*These instructions shall serve as steps to follow to eliminate confusion when a certified individual desires to change employment, or a company wishes to change its name, and maintain U/G certification. The conditions listed in each instance must be met if your are:*

**A. Changing employment to another established company.**

1. *The individual shall submit a new application reflecting changes (co. name, address, fed. I.D. #, etc.) to be accompanied by a \$150.00 non-refundable application fee.*
2. *The individual shall submit insurance forms from new company.*
3. *The individual shall not be required to re-test. (Exception - If the individual has not re-newed certification for over 12 months, a test must be taken to maintain certification.)*

**B. One or more contractors forming a new company.**

1. *All individuals who wish to retain their certification shall submit a new application reflecting changes and accompanied by a non-refundable fee of \$150.00 per application.*
2. *Individuals shall submit new insurance forms reflecting the new company name.*
3. *Individuals shall not be required to re-test. (See Exception)*

**C. Changing the name or address of a company which has certified contractors in its employ.**

1. *The company shall have the same personnel.*
2. *A letter shall be submitted stating the proposed changes. The letter shall clearly state the old information on file at the State Fire Marshal's office and the new information the company wishes to be filed.*
3. *If name change is requested, insurance forms reflecting the new company name shall be submitted.*
4. *Certified individuals shall not be required to re-test. (See Exception)*

*D. Company in which only KY U/G certified contractor leaves its employ.*

- 1. Company shall be de-activated until a new applicant from the company has been tested and certified.*
  - a. New application required and non-refundable application fee of \$300.00, plus a \$50.00 test fee. Current insurance information will also be required.*
  - b. Upon approval of application, applicant will be scheduled for testing at the State Fire Marshal's office.*
  - c. Upon successfully passing the test, a card and certificate will be issued.*
  - d. Company shall be rendered active.*



Directions from Louisville:

I-64 East to Exit 58; turn left off of exit. Go 2.7 miles (9 traffic lights); turn right onto US 460 East (Georgetown Road). Go 1 mile to Sea Hero Road; turn right and proceed to the parking lot.

Directions from Lexington:

I-64 West to Exit 58. Turn right off of exit. Go 2.7 miles (9 traffic lights); turn right onto US 460 East (Georgetown Road). Go 1 mile to Sea Hero Road; turn right and proceed to the parking lot.